



Certificate of conformity n° A 15.070

page 1 of 3

Apparatus: Low-voltage busbar trunking system 1000V (U_e) - 2500A (I_{nA})
- 50Hz (f) - 1000 V (U_i) - 8kV (U_{imp}) - 90kA, 1s (I_{cw}) - 200kA (I_{pk}) - IP55
5 Aluminium Bars (3Ph+N+PE) and Aluminium Housing (E)

Designation: GS-A Compact 2500A

Manufacturer: GERSAN ELEKTRIK TIC. ve SAN. A. S.
Anadolu Yakasi Organize Sanayi Bölgesi Gazi Bulvari No. 39-41 - P.K. 57
34953 TUZLA - ISTANBUL (Turkey)

Applicant: GERSAN ELEKTRIK

Tested by: VEIKI-VNL - BUDAPEST (Hungary)
IPH - BERLIN (Germany)
RST - HENNINGSDORF (Germany)
MPA - DRESDEN (Germany)

The apparatus, constructed in accordance with the description mentioned in the documents listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60439-2 (2005-10) and IEC 61439-6 (2012-05).

The results of the tests carried out fulfil the requirements of the relevant parts of IEC 61439-6 (2012-05), according to sub. 10.1 of IEC 61439-1 (2009-01).

The results are shown in the attached documents according to ACAE procedures. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated in the following.

The General Secretary
Date: 2015.06.15

ACAE is member of:



PRD N°070 B

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

