



Certificate of conformity n° A 15.011

page 1 of 3

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the ACAE.

Apparatus: Low-voltage busbar trunking system 1000V (U_e) - 800A (I_{nA}) - 50Hz (f) - 1000 V (U_i) - 8kV (U_{imp}) - 36kA, 1s (I_{cw}) - 76kA (I_{pk}) - IP55
5 Aluminium Bars (3Ph+N+PE) and Aluminium Housing (E)

Designation: GS-A Compact 500-630-800A

Manufacturer: GERSAN ELEKTRIK TIC. ve SAN. A. S.
Anadolu Yakasi Organize Sanayi Bölgesi Gazi Bulvari No. 39-41 - P.K. 57
34953 TUZLA - ISTANBUL (Turkey)

Applicant: GERSAN ELEKTRIK

Tested by: VEIKI-VNL - BUDAPEST (Hungary)
IPH - BERLIN (Germany)
RST - HENNINGS DORF (Germany)
MPA - DRESDEN (Germany)

The apparatus, constructed in accordance with the description mentioned in the documents listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60439-2 (2005-10).

The results of the tests carried out fulfil the requirements of the relevant parts of IEC 61439-6 (2012-05), according to sub. 10.1 of IEC 61439-1 (2009-01).

The results are shown in the attached documents according to ACAE procedures. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated in the following.

The General Secretary
Date: 2015.02.26



PRD N°070 B

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements