



Certificate of conformity n° A 18.008

page 1 of 3

Apparatus: Low-voltage busbar trunking system 1000V (U_n) - 5000A (I_{nA}) - 50Hz (f) - 1000 V (U_i) - 8kV (U_{imp}) - 120kA, 1s (I_{cw}) - 264kA (I_{pk}) - IP55 5 Copper Bars (3Ph+N+1/2PE) and Aluminium Housing (E)

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus tested, are permitted without written permission from the ACAIE.

Designation: GS-C Compact 5000A

Manufacturer: GERSAN ELEKTRIK TIC. ve SAN. A. S.
Anadolu Yakasi Organize Sanayi Bölgesi Gazi Bulvari No.
39-41-P.K.57, 34953 TUZLA-ISTANBUL (Turkey)

Applicant: GERSAN ELEKTRIK


Tested by: VEIKI-VNL - BUDAPEST (Hungary)
IPH - BERLIN (Germany)
RST - HENNINGS DORF (Germany)
MPA - DRESDEN (Germany)

The apparatus, constructed in accordance with the description mentioned in the documents listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60439-2 (2005-10) and IEC 61439-6 (2012-05).

The results of the tests carried out fulfil the requirements of the relevant parts of IEC 61439-6 (2012-05), according to sub. 10.1 of IEC 61439-1 (2009-01).

The results are shown in the attached documents according to ACAIE procedures. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated in the following.




The General Secretary
Date: 2018.02.26

ACAIE is accredited by



PRD N°070 B

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

ACAIE is member of

