

Test Report No. 7422/VNL

Test Laboratory : VEIKI-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vasgolyó u. 2-4
HUNGARY
Telephone: +36 141 73157
Fax: +36 141 73163
www.vnl.hu

Client : GERSAN ELEKTRIK Tic. ve San. A.Ş.
Anadolu Yakasi Organize Sanayi Bölgesi Gazi Bulvari
No:39-41 34953
Tuzla-Istanbul
TURKEY

Manufacturer : GERSAN ELEKTRIK Tic. ve San. A.Ş.
Anadolu Yakasi Organize Sanayi Bölgesi Gazi Bulvari
No:39-41 34953
Tuzla-Istanbul
TURKEY

Test object : Busbar Trunking System Tap-Off Unit
Type designation : GS COMPACT B5-MCCCB1000
Date(s) of test(s) : 30.07.2012
Date of receipt : 22.05.2012
Test specifications : IEC/EN 60439-2: Ed.3.0 (2000) + A1 (2005)
Test results : The tested tap-off box with built-in MCCB met the requirements of the relevant standard.
8.2.1 Verification of temperature-rise limits – PASSED
8.2.2 Dielectric properties – PASSED
8.2.6 Verification of mechanical operation – PASSED


The Record of Proving Test consists of :


13 pages LOVAG test report forms - oscillograms
2 other pages 5 drawings
- diagrams - photographs


Date of issue : 14.05.2013

Responsible Test Laboratory

Signatures:


/ Lajos Tóth
Responsible for the test


/ Norbert Menyhért /
Supervised by


/ Tibor Tóth /
Responsible observer


/ Dr. László Varga /
Managing director

Note:

The test results relate only to the items tested.
The test report shall not be reproduced except in full
without the written approval of the test laboratory.

